

Approval Number 2206532
Test Report: J-00426847



Water Regulations Approval Scheme Ltd.
Unit 13,
Willow Road,
Pen y Fan Industrial Estate,
Crumlin,
Gwent,
NP11 4EG

6th April 2023

Parsch UK Ltd.
Restoration House,
Drumhead Road,
Chorley North Ind. Park,
Chorley,
PR6 7DE

**WATER REGULATIONS APPROVAL SCHEME LTD. (WRAS)
MATERIAL APPROVAL**

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS6920-1:2000 and/or 2014 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

HOSES & TUBING

5140

'Aquaflex'. Extruded, dual layered hose with an off-white, translucent, polyurethane inner layer and blue NBR rubber outer layer. For use with water up to 23°C.

APPROVAL NUMBER: 2206532
APPROVAL HOLDER: PARSCH UK LTD.

The Scheme reserves the right to review approval.
Approval 2206532 is valid between June 2022 and June 2027

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect on water quality".

The Directory may be found at: www.wrasapprovals.co.uk/approvals-directory/

Yours Faithfully

A handwritten signature in blue ink, appearing to read 'Ian Hughes', with a stylized flourish at the end.

Ian Hughes
WRAS Approvals Manager